

## CU 1000V XLPE Insulation AIA PVC Jacket. XHHW-2 Teck

1000V Multi Conductor, 14-10 AWG Copper, FT4 - Flame Retardancy Rating, XLPE Insulation, Aluminum Interlocked Armor, Sunlight Resistant, Direct Buried, 90°C




Image not to scale. See Table 1 for dimensions.

### CONSTRUCTION:

- Conductor:** Class B stranded copper, compressed in accordance with ASTM B3 and B8.
- Insulation:** Cross-Linked Polyethylene (XLPE).
- Grounding Conductor:** Uninsulated Class B stranded grounding conductor
- Inner Jacket:** Black Polyvinyl Chloride (PVC)
- Armor:** Aluminum Interlocked Armor (AIA)
- Overall Jacket:** Black PVC (optional colors available)

### APPLICATIONS AND FEATURES:

For exposed or concealed wiring in wet or dry locations. For use in ventilated, non-ventilated and ladder type cable troughs and ventilated flexible cableway in wet, dry, hazardous locations or direct buried. Sunlight Resistant. Typical applications are for control, lighting and power circuits in: pulp and paper mills, steel mills, food processing plants, commercial centers, mines, generating stations, refineries, industrial plants and chemical plants.

### SPECIFICATIONS:

- ASTM B3 Soft or Annealed Copper Wire
- ASTM B8 Concentric-Lay-Stranded Copper Conductors
- UL 44 Thermoset-Insulated Wires and Cables
- UL 1569 Metal-Clad Cables
- UL 1685 Vertical-Tray Fire Propagation and Smoke Release Test
- CSA C22.2 No. 174 Cables in Hazardous Locations
- CSA C22.2 No. 131 Type TECK 90 Cable
- CSA AG14 - Acid Gas Compliance
- ICEA S-58-679 Control Cable Conductor Identification Method 1 Table 2
- ICEA S-95-658 (NEMA WC70) Power Cables Rated 2000 Volts or Less for the Distribution of Electrical Energy

### SAMPLE PRINT LEGEND:

{SQMTR\_DUAL} SOUTHWIRE{R} {CSA} LL90458 X/C XXX AWG (XX{mm<sup>2</sup>}) CU TECK 90 XLPE -40{D}C FT4 AG14 SUN. RES. 90{D}C 1000V HL --- {UL} E96627 TYPE MC XLPE 600V SUN. RES. DIRECT BURIAL 90{D}C --- {NOM}-ANCE Tipo MC XHHW-2 CT FT4 600V 1000V 90{D}C USA



Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | [www.southwire.com](http://www.southwire.com)



Southwire

**CABLETECH  
SUPPORT™**

Services

## Table 1 – Weights and Measurements

Stock Number	Cond. Size	Cond. Number	Strand Count	Diameter Over Conductor	Insul. Thickness	Ground	Inner Jacket Thickness	Dia. Over Armor	Jacket Thickness	Approx. OD	Copper Weight	Approx. Weight
	AWG/ Kcmil		No. of Strands	inch	mil	No. x AWG	mil	inch	mil	inch	lb/1000ft	lb/1000ft
TBA	14	2	7	0.070	45	1 x 14	60	0.550	50	0.750	34	230
563522	14	3	7	0.070	45	1 x 14	60	0.660	50	0.760	51	257
TBA	14	4	7	0.070	45	1 x 14	60	0.604	50	0.817	64	289
567121	12	2	7	0.088	45	1 x 14	60	0.669	50	0.769	60	258
563526	12	3	7	0.088	45	1 x 14	60	0.698	50	0.798	81	296
TBA	12	4	7	0.088	45	1 x 14	60	0.648	50	0.860	101	342
TBA	10	2	7	0.113	45	1 x 12	60	0.636	50	0.836	96	312
562297	10	3	7	0.113	45	1 x 12	60	0.781	50	0.881	129	384
TBA	10	4	7	0.113	45	1 x 12	60	0.838	50	0.921	161	419

All dimensions are nominal and subject to normal manufacturing tolerances

◊ Cable marked with this symbol is a standard stock item

## Table 2 – Electrical and Engineering Data

Stock Number	Cond. Size	Cond. Number	Min Bending Radius	DC Resistance @ 25°C	AC Resistance @ 75°C	Inductive Reactance @ 60Hz	Allowable Ampacity At 60°C	Allowable Ampacity At 75°C	Allowable Ampacity At 90°C
	AWG/ Kcmil		inch	Ω/1000ft	Ω/1000ft	Ω/1000ft	Amp	Amp	Amp
TBA	14	2	5.2	2.631	3.170	0.058	15	20	25
563522	14	3	5.3	2.631	3.170	0.058	15	20	25
TBA	14	4	5.7	2.631	3.170	0.058	12	16	20
567121	12	2	5.3	1.662	2.002	0.054	20	25	30
563526	12	3	5.5	1.662	2.002	0.054	20	25	30
TBA	12	4	6.0	1.662	2.002	0.054	16	20	24
TBA	10	2	5.8	1.040	1.253	0.050	30	35	40
562297	10	3	6.1	1.040	1.253	0.050	30	35	40
TBA	10	4	6.4	1.040	1.253	0.050	24	28	32

\* Ampacities based upon 2023 NEC Table 310.16 and do not take into account the overcurrent protection limitations in NEC 240.4(D) of 15 Amps for 14 AWG CU, 20 Amps for 12 AWG CU, and 30 Amps for 10 AWG CU (independent of the conductor temperature rating and stranding if size is present in table). Also, see NEC sections 310.15 and 110.14(C) for additional requirements.

\* Ampacities have been adjusted for more than Three Current-Carrying Conductors.

