


# HVTECK CU 1/C 280TRXLPE CB PVC AIA PVC 28kV 100% CSA

Single Conductor, 280 Mils Tree Retardant Cross Linked Polyethylene, 100% Insulation Level, Concentric Bond, Polyvinyl Chloride (PVC) Inner Jacket, Aluminum Interlocked Armour (AIA), Polyvinyl Chloride (PVC) Jacket



## **CONSTRUCTION:**

- 1. Conductor: Class B compressed stranded bare copper per ASTM B3 and ASTM B8
- 2. Conductor Shield: Semi-conducting cross-linked copolymer
- 3. Insulation: 280 Mils Tree Retardant Cross Linked Polyethylene 100% insulation level
- 4. Insulation Shield: Strippable semi-conducting cross-linked copolymer
- 5. **Concentric Shield:** Concentrically applied copper bond / shield wires. Complies with greater than the minimum requirement as per Table 44, CSA Standard C68.10 and Table 16A, Canadian Electrical Code Part 1
- 6. Neutral Separator: Mylar tape
- 7. Inner Jacket: PVC inner jacket
- 8. Armour: Aluminum Interlocked Armour (AIA)
- 9. **Overall Jacket:** Black Polyvinyl Chloride (PVC) Jacket

# **APPLICATIONS AND FEATURES:**

Southwire's 28kV HVTECK is a CSA armoured cable for industrial and commercial medium voltage applications. Rated FT4, -40°C, Hazardous Locations (HL). These cables are capable of operating continuously at the conductor temperature not in excess of 105°C for normal operation, 140°C for emergency overload, and 250°C for short circuit conditions. Rated for 1000 lbs /FT maximum sidewall pressure. These cables feature sunlight and moisture resistance, exceptional corona resistance, resistance to most chemical soils and acids and are flame retardant.

# **SPECIFICATIONS**:

- ASTM B3 Soft or Annealed Copper Wire
- ASTM B8 Concentric-Lay-Stranded Copper Conductors
- CSA C22.2 No. 174 Cables in Hazardous Locations
- CSA C22.2 No. 2556 & No. 0.3 Wire and Cable Test Methods
- CSA C68.10 Shielded Power Cables for Commercial and Industrial Applications 5 to 46 KV
- CSA C68.3 Shielded & Concentric Neutral Power Cable 5 to 46 kV
- CSA LTGG [-40°C] as per C68.10 for Cold Bend and Impact rating
- CSA HL for Hazardous Locations rating
- CSA SUN RES for Sunlight Resistant rating
- ICEA S-93-639 (NEMA WC 74) 5-46 KV Shielded Power Cable
- ICEA T-29-520 Flame Test (210,000 BTU/Hr)
- IEEE 383 Flame Test (70,000 btu)



Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | www.southwire.com



- IEEE 1202 FT4 Flame Test (70,000) BTU/hr Vertical Tray Test (1/0 and Larger)
- FT1 Flame Test (1,706 BTU/Hr nominal Vertical Wire Flame Test)
- AEIC CS-8 Specification for extruded dielectric shielded power cables rated for 5 through 46KV (Qualification Test Requirements)

#### **SAMPLE PRINT LEGEND**:

(CSA) SOUTHWIRE (NESC) #P# 1/C [#AWG or #kcmil] CU 280 TRXLPE AIA 28kV 100% INS LEVEL CB [No. x SIZE] AWG SUN RES 105°C FT4 HL (-40°C) LTGG RoHS YEAR [SEQUENTIAL METER MARKS]

#### Table 1 – Weights and Measurements

| Cond.<br>Size | Strand | Diameter<br>Over<br>Conductor | Diameter<br>Over<br>Insulation | Insul.<br>Thickness | Diameter Over<br>Insulation<br>Shield | Concentric<br>Neutral | Inner Jacket<br>Thickness | Dia. Over<br>Armour | Overall<br>Jacket<br>Thickness | Approx.<br>OD | Copper<br>Weight | Approx.<br>Weight |
|---------------|--------|-------------------------------|--------------------------------|---------------------|---------------------------------------|-----------------------|---------------------------|---------------------|--------------------------------|---------------|------------------|-------------------|
| AWG/<br>Kcmil | No.    | inch                          | inch                           | mil                 | inch                                  | No. x AWG             | mil                       | inch                | mil                            | inch          | lb/<br>1000ft    | lb/1000ft         |
| 3/0           | 19     | 0.456                         | 1.054                          | 280                 | 1.114                                 | 13x14                 | 80                        | 1.758               | 60                             | 1.878         | 694              | 1803              |

All dimensions are nominal and subject to normal manufacturing tolerances

 $\Diamond$  Cable marked with this symbol is a standard stock item

1 Comply with ICEA S-93-639 Appendix C for jacket thickness determination

TBA stock codes are estimations only and actual product may vary. Please wait until a stock code is assigned to purchase connectors and/or fittings.

## **Table 2 – Electrical and Engineering Data**

| Cond.<br>Size | Min<br>Bending<br>Radius | Max Pull<br>Tension | DC<br>Resistance<br>@ 25°C | AC<br>Resistance<br>@ 90°C | Capacitive<br>Reactance @<br>60Hz | Inductive<br>Reactance<br>@ 60Hz | Zero<br>Sequence<br>Impedance | Positive<br>Sequence<br>Impedance | Phase<br>Short<br>Circuit<br>Current @<br>6 Cycles | Allowable<br>Ampacity In<br>Air 90°C | Allowable<br>Ampacity<br>Directly<br>Buried 90°C |
|---------------|--------------------------|---------------------|----------------------------|----------------------------|-----------------------------------|----------------------------------|-------------------------------|-----------------------------------|--|--------------------------------------|--|
| AWG/<br>Kcmil | inch                     | lb                  | Ω/1000ft                   | Ω/1000ft                   | MΩ*1000ft                         | Ω/1000ft                         | Ω/1000ft                      | Ω/1000ft                          | Amp  | Amp                                  | Amp  |
| 3/0           | 22.5                     | 1342                | 0.064                      | 0.081                      | 0.054                             | 0.054                            | 0.427 +<br>j0.315             | 0.082 +<br>j0.054                 | 10137  | 356                                  | 333  |

\* Inductive impedance is based on non-ferrous conduit with one diameter spacing center-to-center.

\* CEC ampacities are based on:

3-1/C in air copper and aluminum: D17M

3-1/C direct buried copper and aluminum: D17A

#### Table 3 – Weights and Measurements (Metric)

| Cond.<br>Size | Strand | Diameter<br>Over<br>Conductor | Diameter<br>Over<br>Insulation | Insul.<br>Thickness | Diameter Over<br>Insulation<br>Shield | Concentric<br>Neutral | Inner Jacket<br>Thickness | Dia. Over<br>Armour | Overall<br>Jacket<br>Thickness | Approx.<br>OD | Copper<br>Weight | Approx.<br>Weight |
|---------------|--------|-------------------------------|--------------------------------|---------------------|---------------------------------------|-----------------------|---------------------------|---------------------|--------------------------------|---------------|------------------|-------------------|
| AWG/<br>Kcmil | No.    | mm                            | mm                             | mm                  | mm                                    | No. x AWG             | mm                        | mm                  | mm                             | mm            | kg/km            | kg/km             |
| 3/0           | 19     | 11.58                         | 26.77                          | 7.11                | 28.30                                 | 13x14                 | 2.03                      | 44.65               | 1.52                           | 47.70         | 1033             | 2683              |

All dimensions are nominal and subject to normal manufacturing tolerances

**◊** Cable marked with this symbol is a standard stock item

1 Comply with ICEA S-93-639 Appendix C for jacket thickness determination

TBA stock codes are estimations only and actual product may vary. Please wait until a stock code is assigned to purchase connectors and/or fittings.

# Table 4 – Electrical and Engineering Data (Metric)

| 3/0 | 571.50 | 5972 | 0.2100 | 0.27 | 0.0165 | 0.1772 | 0.427 +<br>j0.315 | 0.082 +<br>j0.054 | 10137 | 356 | 333 |  |
|-----|--------|------|--------|------|--------|--------|-------------------|-------------------|-------|-----|-----|--|
|-----|--------|------|--------|------|--------|--------|-------------------|-------------------|-------|-----|-----|--|



Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | www.southwire.com



\* Inductive impedance is based on non-ferrous conduit with one diameter spacing center-to-center.

\* CEC ampacities are based on:

3-1/C in air copper and aluminum: D17M

3-1/C direct buried copper and aluminum: D17A

Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | www.southwire.com