

# EPEC 80 (Schedule 80)



Image not to scale. See Table 1 for dimensions.

#### **CONSTRUCTION:**

High-Density Polyethylene (HDPE)

### **APPLICATIONS AND FEATURES:**

Designed to house and protect wire and cable products in various underground applications for commercial constructions, EV infrastructure expansions, Utility grid-hardening efforts, airports, mass transit, renewables, petrochemical, agriculture, and data centers. May be installed directly buried or encased in concrete as permitted by The National Electrical Code® Article 353. For above ground applications, HDPE conduit must be encased in a minimum of 2 inches of concrete.

### **SPECIFICATIONS:**

- ASTM D3350 Standard Specification for Polyethylene Plastics Pipe and Fittings Materials
- ASTM F2160 Standard Specification for Solid Wall High Density Polyethylene (HDPE) Conduit Based on Controlled Outside Diameter (OD)
- UL 651A High Density Polyethylene (HPDE) Conduit
- CSA <u>CSA marking is available upon request</u>
- Buy American: Compliant with Buy American Requirements, found in 49 U.S.C. § 5323(j); specify "Made in the USA Only!" when ordering to ensure your project receives American made products.
- NEMA TC-7 Smooth-Wall Coilable Electrical Polyethylene Conduit

#### **SAMPLE PRINT LEGEND:**

{SQFTG} FEET (LOGO) SOUTHWIRE CONDUIT (UL) HDPE X" SCH80 NEMA TC 7 / ASTM F2160 {MMM/DD/YYYY} {MACH/ SHFT/OP}





## **Table 1 – Physical and Electrical Data**

Description	Duct Nominal Size inch	Duct Nominal Outside Dia. inch	Duct Min. Wall Thickness inch	Duct Nominal Inside Dia. inch	Duct Min. Bending Radius inch	Duct Max. Pull Tension Ib	Duct Color	Approx. Cable and Duct Weight Ib/1000ft
EPEC 80 (Schedule 80)	3.00	3.500	0.300	3.786	39	6420	Optional	1325

All dimensions are nominal and subject to normal manufacturing tolerances

 $\Diamond$  Cable marked with this symbol is a standard stock item

TBA stock codes are estimations only and actual product may vary. Please wait until a stock code is assigned to purchase connectors and/or fittings.

# **Cell Classification for HDPE Conduit**

Property	Test Method	Value		
Density	D4883	0.953 g/cc		
Melt Index	D1238	0.25 g/10 min		
Flexural Modulus	D790	168,000 psi		
Tensile Strength	D638	3900 yield @ 2 in/min		
SP-NCLS ESCR	F2136	>1000 hrs		
Hydrostatic Design Basis	D2837	N/A		

• (PE436580C-BK), (PE436580E-Colors)





Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | www.southwire.com