


MC-PCS HCF Duo[™] Power & Control/Signal Cable 120/208V Colors

Copper THHN/THWN Insulated Singles. Green Insulated Copper Grounding Conductor. UL Listed. 600 Volts Rated VW-1. Lightweight Interlocked Armor. Signal: 16 AWG Copper TFN insulated singles.



CONSTRUCTION:

- 1. **Conductor:** Solid copper per ASTM B3
- 2. Insulation: All phases are insulated with Polyvinyl Chloride with Nylon Sheath Type THHN/THWN
- 3. Ground: Green insulated ground. Polyvinyl Chloride with Nylon Sheath Type THHN/THWN
- 4. **Signal:** 16 AWG Copper TFN Insulated Singles Pink, Purple. Overall light blue jacket over the signal cables
- 5. Binder: Mylar tape
- 6. **Ground:** Full-sized bare 8000 series aluminum grounding/bonding conductor. Armor and bare aluminum conductor form the equipment ground path.
- 7. Armor: Lightweight Interlocked Armor

APPLICATIONS AND FEATURES:

Southwire MC-PCS HCF Duo™ Type MC All Purpose Hospital Care Facility Cable is suitable for use as follows:

- Branch-circuit wiring for patient care areas of hospitals, medical centers, and other health care facilities (when installed in accordance with NEC® Articles 517 and 330, and mechanically protected per Article 300.4). Such areas include nursing homes, dental offices, clinics, and outpatient facilities. Use in hazardous anesthetizing areas is prohibited.

- Applications requiring redundant, dedicated or isolated grounding paths.
- Fished or embedded in plaster.
- Concealed or exposed installations.
- Environmental air-handling spaces per NEC 300.22 (C).
- Places of Assembly per NEC 518.4 and theaters per NEC 520.5.
- Power, lighting, control, and signal circuits.
- Installation in cable tray and approved raceways.
- Under raised floors for information technology equipment conductors and cables per NEC Article 645.5
- Class I Div. 2, Class II Div 2, & Class III Div. 1 Hazardous Locations.
- Use with UL Listed MCI-A fittings.
- Binder tape with print legend wrapped around assembly.
- Type THHN/THWN rated 90°C Dry.
- Anti-Short bushing not required

Southwire MC-PCS HCF Duo™ Type MC Cable - meets or exceeds the following requirements:

- UL Online Product Guide Info Metal-Clad Cable (PJAZ) (www.ul.com)
- Federal Specification A-A59544 (formerly J-C-30B)



Southwire Company, LLC | One Southwire Drive, Carrollton, GA 30119 | www.southwire.com



- NFPA 70 (National Electrical Code), Article 330
- Listed for use in UL 1, 2 and 3 Hour Through Penetration Firestop Systems

SPECIFICATIONS:

- ASTM B3 Soft or Annealed Copper Wire
- ASTM B8 Concentric-Lay-Stranded Copper Conductors
- UL 83 Thermoplastic Insulated Wires and Cables
- UL 1569 Metal-Clad Cables
- UL 1479 Standard for Safety Fire Tests of Penetration Firestops
- UL 1685 FT4 Vertical-Tray Fire Propagation and Smoke Release Test
- IEEE 1202 FT4 Flame Test (70,000) BTU/hr Vertical Tray Test
- Buy American: Compliant with Buy American Requirements, found in 49 U.S.C. § 5323(j); specify "Made in the USA Only!" when ordering to ensure your project receives American made products.
- VW-1 (Vertical-Wire) Flame Test

SAMPLE PRINT LEGEND:

ALUMINUM CLAD CABLE WITH COPPER CDRS TYPE THHN OR THWN MAX VOLTAGE 600V, FOR USE IN CABLE TRAY90(D)C - WET OR DRY LOCATIONS GASOLINE & OIL RESISTANT CDRS LISTED FOR FIREWALL PENTRATION (GREEN INSULATED GROUND)

Cond. Size	Conductor Number	Color	Diameter Over Conductor	Conductor Stranding	Insulation Thickness	Ground Size	Diameter Over Armor	Copper Weight	Overall Weight
AWG/ Kcmil			inch		mils	No. x AWG	inch	lbs/1000ft	lbs/1000ft
				12 AWG Solid					
12	2	BK,WE	0.080	Solid	20	1x12	0.631	75	164
12	2	RD,WE	0.080	Solid	20	1x12	0.632	75	164
12	2	BE,WE	0.080	Solid	20	1x12	0.632	75	164
12 AWG 19 Strands									
12	2	BK,WE	0.080	19	20	1x12	0.651	76	170
12 AWG Solid									
12	3	BK,RD,WE	0.080	Solid	20	1x12	0.674	95	193
			12	AWG 19 Stran	ds				
12	3	BK,RD,WE	0.080	19	20	1x12	0.697	96	198
				10 AWG Solid					
10	2	BK,WE	0.101	Solid	25	1x10	0.697	108	215
	Size AWG/ Kcmil 12 12 12 12 12 12 12 12	Size Number AWG/ Kcmil 12 2 12 2 12 2 12 2 12 2 12 3 12 3 12 3	Size Number Color AWG/ Kcmil 2 2 BK,WE 12 2 RD,WE 12 2 BE,WE 12 2 BE,WE 12 2 BK,WE 12 3 BK,RD,WE 12 3 BK,RD,WE	Size Number Color Conductor AWG/ Kcmil inch inch 12 2 BK,WE 0.080 12 2 RD,WE 0.080 12 2 BE,WE 0.080 12 2 BE,WE 0.080 12 2 BE,WE 0.080 12 2 BK,RD,WE 0.080 12 3 BK,RD,WE 0.080 12 3 BK,RD,WE 0.080	Size Number Color Conductor Stranding AWG/ Kcmil inch inch 12 AWG Solid 12 2 BK,WE 0.080 Solid 12 2 RD,WE 0.080 Solid 12 2 BE,WE 0.080 Solid 12 2 BE,WE 0.080 Solid 12 2 BE,WE 0.080 Solid 12 2 BK,RD 0.080 Solid 12 3 BK,RD,WE 0.080 19 12 3 BK,RD,WE 0.080 Solid 12 3 BK,RD,WE 0.080 19 12 3 BK,RD,WE 0.080 19 12 3 BK,RD,WE 0.080 19	Size Number Color Conductor Stranding Thickness AWG/ Kcmil inch inch mils 12 2 BK,WE 0.080 Solid 20 12 2 RD,WE 0.080 Solid 20 12 2 RD,WE 0.080 Solid 20 12 2 BE,WE 0.080 Solid 20 12 2 BE,WE 0.080 Solid 20 12 2 BE,WE 0.080 Solid 20 12 2 BK,RD 0.080 19 20 12 3 BK,RD,WE 0.080 Solid 20 12 3 BK,RD,WE 0.080 Solid 20 12 3 BK,RD,WE 0.080 19 20 12 3 BK,RD,WE 0.080 19 20	SizeNumberColorConductorStrandingThicknessSizeAWG/ KcmilinchinchmilsNo. x AWG122BK,WE0.080Solid201x12122RD,WE0.080Solid201x12122BE,WE0.080Solid201x12122BE,WE0.080Solid201x12122BE,WE0.080Solid201x12122BK,WE0.08019201x12123BK,RD,WE0.080Solid201x12123BK,RD,WE0.080Solid201x12123BK,RD,WE0.080Solid201x12123BK,RD,WE0.08019201x12123BK,RD,WE0.08019201x12123BK,RD,WE0.08019201x12	Size Number Color Conductor Stranding Thickness Size Armor AWG/ Kcmil inch inch mils No. x AWG inch inch 12 2 BK,WE 0.080 Solid 20 1x12 0.631 12 2 BK,WE 0.080 Solid 20 1x12 0.632 12 2 BK,WE 0.080 19 20 1x12 0.651 12 3 BK,RD,WE 0.080 Solid 20 1x12 0.674 12 3 BK,RD,WE 0.080 19 20 1x12 0.697 12 3 BK,RD,WE 0.080 1	Size Number Color Conductor Stranding Thickness Size Armor Weight AWG/ Kcmil inch inch mils No. x AWG inch Ibs/1000ft 12 2 BK,WE 0.080 Solid 20 1x12 0.631 75 12 2 RD,WE 0.080 Solid 20 1x12 0.632 75 12 2 BE,WE 0.080 Solid 20 1x12 0.632 75 12 2 BE,WE 0.080 Solid 20 1x12 0.632 75 12 2 BK,RD 0.080 19 20 1x12 0.651 76 12 3 BK,RD,WE 0.080 Solid 20 1x12 0.674 95 12 3 BK,RD,WE 0.080 19 20 1x12 0.697 96 12 3 BK,RD,WE 0.080 19 20<

Table 1 – Weights and Measurements

All dimensions are nominal and subject to normal manufacturing tolerances

 \Diamond Cable marked with this symbol is a standard stock item

Note: Conductor number = number of phase conductors plus neutral. Does not include green ground.

TBA stock codes are estimations only and actual product may vary. Please wait until a stock code is assigned to purchase connectors and/or fittings.





Table 2 – Electrical and Engineering Data

Cond. SizeConductor NumberMin. Bend RadiusDC Resistance at 25°CAC Resistance at 75°CInductive Reactance @ 60HzAllowable Ampacity Raceway 75°CAllowable Ampacity Raceway 9AWG/ KcmilInchesΩ/1000ftΩ/1000ftΩ/1000ftΩ/1000ftAmpAmp1224.41.6622.0020.05425301224.41.6622.0020.05425301224.41.6622.0020.05425301224.41.6622.0020.05425301224.41.6622.0020.05425301224.41.6622.0020.05425301224.61.6622.0020.05425301224.61.6622.0020.0542530											
Kcmil Incres Ω/10001 Ω/10001 Ω/10001 Ω/10001 Δ/10001 Δ/10001 <thδ 10001<="" th=""> <thδ 10001<="" th=""> <thδ 1<="" td=""><td></td></thδ></thδ></thδ>											
12 2 4.4 1.662 2.002 0.054 25 30 12 2 4.4 1.662 2.002 0.054 25 30 12 2 4.4 1.662 2.002 0.054 25 30 12 2 4.4 1.662 2.002 0.054 25 30 12 AWG 19 Strands											
12 2 4.4 1.662 2.002 0.054 25 30 12 2 4.4 1.662 2.002 0.054 25 30 I2 AWG 19 Strands											
12 2 4.4 1.662 2.002 0.054 25 30 12 AWG 19 Strands											
12 AWG 19 Strands											
12 2 4.6 1.662 2.002 0.054 25 30	12 AWG 19 Strands										
12 AWG Solid											
12 3 4.7 1.662 2.002 0.054 25 30											
12 AWG 19 Strands											
12 3 4.9 1.662 2.002 0.054 25 30											
10 AWG Solid											
10 2 4.9 1.040 1.253 0.050 35 40											

* Ampacities based upon 2023 NEC Table 310.16 and do not take into account the overcurrent protection limitations in NEC 240.4(D) of 15 Amps for 14 AWG CU, 20 Amps for 12 AWG CU, and 30 Amps for 10 AWG CU (independent of the conductor temperature rating and stranding if size is present in table). Also, see NEC sections 310.15 and 110.14(C) for additional requirements.